

# 3. PLANNING OF NATIONAL POWER SYSTEMS


Asko Vuorinen




# System conditions




Site	South-Europe
Site temperature	+30 °C
Site elevation	200 m
Peak load of power system	10 000 MW





# Historical prices of fuels





# Future prices of fuels by regression analysis






# Levelised prices of fuels

Calculated by discounting future prices to first year of operation (2011):

$$FI = \frac{\sum (f(i)/(1-r/100)^i)}{\sum (e(i)/(1-r/100)^i)}$$

where

- FI = levelised price
- f(i) = fuel price in year i
- e(i) = energy generation in year i
- r = discount rate (=8 %)




# Levelised prices of fuels, (eur/MWh lhv)



	2013 price	levelised price
Liquid biofuel (lbf)	38,8	43,4
Light fuel oil (lfo)	36,7	47,4
Heavy fuel oil (hfo)	24,4	31,8
Natural gas*	24,4+2	31,3+2
Coal	7.9	9.3
Nuclear	2,4	2,8

\* Natural gas has variable and fixed (2) components



# Cost estimates of power plants

- Power plant options
- Capital costs
- Operation and maintenance costs
- Fuel costs
- Tariff formulas



# Alternative power plants

- Oil-fired plants
- Gas-fired plants
- Other plants





# Oil-fired power plants




Plant	Concept
DE-160 hfo*	10 x 16 MW diesel engines
DE-160 lfo**	20 x 8 MW diesel engines
ADGT-160 lfo	4 x 40 MW gas turbines
Ind.GT-110 lfo	1 x 110 MW gas turbine
DE-160 lbf***	10 x 16 MW diesel engines

\*hfo = heavy fuel oil

\*\*lfo = light fuel oil

\*\*\*lbf= liquid bio fuel (palm oil/rape seed oil)



# Oil-fired power plants, Performance




Plant	Net efficiency (%)	CO2-emission (g/kWh)
DE-160 hfo	43 %	654
DE-160 lfo	41 %	644
ADGT-160 lfo	36 %	712
Ind.GT-110 lfo	31 %	860
DE-160 lbf	41 %	-



# Oil-fired power plants, Capital costs




Plant	Investment €/kW	Capital costs €/kWa
DE-160 hfo	991	93,6
DE-160 lfo	756	71,5
DE-160 lbf	980	92,6
ADGT-160 lfo	857	80,9
Ind.GT-110 lfo	635	60,0



# Oil-fired power plants, Fixed O&M costs (FOM)

Plant	Personnel €/kW <sub>a</sub>	Other €/kW <sub>a</sub>	Total €/kW <sub>a</sub>
DE-160 hfo	12.5	5.9	18,4
DE-160 lfo	2.9	4.9	7.8
DE-160 lbf	6.5	5.8	12.2
ADGT-160 lfo	3.0	5.3	8.4
Ind.GT-110 lfo	4.5	5.4	9.9




# Oil-fired power plants, Variable O&M costs (VOM)

Plant	Maintenance €/MWh*	Materials €/MWh	Waste** €/MWh	Total €/MWh
DE-160 hfo	6.0	3.5	16.7	26.3
DE-160 lfo	4.8	3.3	16.1	24.2
DE-160 lbf	6.0	3.1	-	9.1
ADGT-160 lfo	4.8	7.4	18.0	30.2
Ind.GT-110 lfo	4.8	17.8	21.5	44.1

\*Includes start-up costs lfo plant run 2 h/startup (gas turbines consume 5 eq.hours/start-up)

\*\* includes CO<sub>2</sub> costs (23 eur/ton CO<sub>2</sub>)



# Oil-fired power plants, Tariff formulas

Plant	Fixed costs €/kW <sub>a</sub>	Variable costs €/MWh	Gen. costs at 500 h/a €/MWh
DE-160 hfo	113.5	102.5	330
DE-160 lfo	81.5	138.7	<b><u>302</u></b>
DE-160 lbf	106.9	113.9	328
ADGT-160 lfo	91.8	158.1	342
Ind.GT-110 lfo	72.8	197.3	343



# Gas-fired power plants, Concepts




Plant

Concept

---

GTCC-500 gas	300 MW GT+ 200 MW ST
GTCC-330 gas	2 x 110 MW GT + 110 ST
DF-160 gas	10 x 16 MW dual-fuel engines
GE-160 gas	20 x 8 MW gas engines
ADGT-160 gas	4 x 40 MW gas turbines
Ind.GT-110 gas	1 x 110 MW gas turbine
CHP-160 gas	20 x 8 MW gas engines or 110 GT and 50 MW ST

---



# Gas-fired power plants, Performance

Plant	Net efficiency (%)	CO <sub>2</sub> -emission (g/kWh)
GTCC-500 gas	58 %	350
GTCC-330 gas	49 %	414
DF-160 gas	43 %	474
GE-160 gas	42 %	482
ADGT-160 gas	38 %	529
Ind.GT-110 gas	31 %	646
CHP-160 gas*	42 %(86%)	238


\* Combined heat and power (CHP) plant has 86 % total efficiency






# Gas-fired power plants, Capital costs

Plant	Investment (€/kW)	Capital costs (€/MWh)
GTCC-500 gas	1316	124,4
GTCC-330 gas	1244	117.5
DF-160 gas	984	92.9
GE-160 gas	915	86.4
ADGT-160 gas	1036	97.9
Ind.GT-110 gas	752	71.0
CHP-160 gas	999	94.4



# Gas-fired power plants, Fixed O&M costs (FOM)


Plant	Personnel (€/kW)	Other (€/kW)	Total (€/kW)
GTCC-500 gas	8.3	5.9	14.2
GTCC-330 gas	11.6	5.9	17.5
DF-160 gas	6.8	5.9	12.6
GE-160 gas	6.7	5.6	12.2
ADGT-160 gas	6.7	6.0	12.7
Ind.GT-110 gas	9.9	5.8	15.8
CHP-160 gas	6.7	5.9	12.6



# Gas-fired power plants, Variable O&M costs (VOM)

Plant	Maintenance €/MWh	Materials €/MWh	Waste* €/MWh	Total €/MWh
GTCC-500 gas	3.6	3.5	8.8	15.9
GTCC-330 gas	3.6	3.7	10.5	17.8
DF-160 gas	4.8	1.6	11.9	18.3
GE-160 gas	4.8	1.6	12.1	18.5
ADGT-160 gas	4.8	5.9	13.4	24.0
Ind.GT-110 gas	4.8	4.5	16.3	25.6
CHP-160 gas	4.8	1.2	5.9	11.9

\* Includes CO<sub>2</sub>-costs at price 23 €/t CO<sub>2</sub>



# Gas-fired power plants, Tariff formulas

Plant	Fixed costs €/kW <sub>a</sub>	Variable costs €/MWh	Gen.costs at 2000 h/a €/MWh
GTCC-500 gas	155.9	66.7	<b>145</b>
GTCC-330 gas	155.8	78.6	157
DF-160 gas	130.4	87.1	152
GE-160 gas	122.6	88.5	150
ADGT-160 gas	137.1	101.5	170
Ind.GT-110 gas	119.1	120.3	180
CHP-160 gas	130.8	49.0	<b><u>114</u></b>



# Other power plants



Plant

Concept

---

Nuclear-1500

1500 MW (Evolutionary PWR)

Coal-500


Supercritical steam plant

Biomass-150

150 MW wood chip fired plant

Wind-150

30 x 5 MW wind park



# Other power plants Performance



Plant	Efficiency (%)	CO2-emission (g/kWh)
Nuclear-1500	35 %	-
Coal-500	40 %	858
Biomass-150	34 %	-
Wind-150	-	-



# Other power plants


## Capital costs



Plant	Investment costs (€/kW)	Capital costs (€/kW <sub>a</sub> )
-------	----------------------------	---------------------------------------

---

Nuclear-1500	3205	302.8
Coal-500	1794	169.5
Biomass-160	1812	171.2
Wind-160	1440	136.1



# Other power plants

## Fixed O&M costs (FOM)



Plant	Personel costs €/kW <sub>a</sub>	Other costs €/kW <sub>a</sub>	Total costs €/kW <sub>a</sub>
-------	--	-------------------------------------	-------------------------------------

---

Nuclear-1500	15.2	13.0	28.2
Coal-500	11.5	7.8	19.3
Biomass-160	25.6	9.2	34.9
Wind-160	7.4	7.9	15.3






# Other power plants

## Variable O&M costs (VOM)



Plant	Maintenance €/MWh	Materials €/MWh	Waste €/MWh	Total €/MWh
Nuclear-1500	4.8	2.0	0	6.8
Coal-500	3.6	3.0	21.4*	24.7
Biomass-160	2.0	1.0	-	3.0
Wind-160	10.0	1.0	-	11.0

\* includes CO2 costs




# Other power plants


## Tariff formulas


Plant	Fixed costs €/kW <sub>a</sub>	Variable costs €/MWh	Gen. costs at 7000 h/a €/MWh
Nuclear-1500	336.1	14.7	<b><u>62.7</u></b>
Coal-500	197.8	51.4	79.7
Biomass-150	206.9	49.0	78.6
Wind-150	151.4	11.0	<b><u>61.7*</u></b>
CHP-160 gas	130.8	49.0	67.1

\* At 3000 h/a



# Generation costs






# Break even costs

Full power hours (t) when the alternative power plants have the same generation costs

$$VC_1 \times t + FC_1 = VC_2 \times t + FC_2$$

Then

$$t = (FC_2 - FC_1) / (VC_1 - VC_2)$$



# Break even costs


- 1)  $< 149$  h/a Ind. GT cheapest (LFO)
- 2)  $> 149$  h/a diesel engine is cheaper than GT
- 3)  $> 820$  h/a gas engine is cheaper than DE
- 4)  $> 1530$  h/a GTCC-500 is cheaper than GE
- 5)  $> 2740$  coal plant is cheaper than GTCC
- 6)  $> 3770$  h/a nuclear plant cheaper than coal
- 7) between 770 - 5800 h/a CHP plant is cheaper than others

If nuclear and coal plants are not accepted


- 4) GTCC plant is cheapest 1530-8766 h/a

Renewable plants

- 1)  $< 1125$  h/a LBF diesel plant
- 2)  $> 1125$  h/a biomass plant and wind plants




# Minimizing of the total costs




- Fill the load duration curves using the least cost alternatives




# Case 1) All options available






# Case 2) No nuclear

Note: coal replaces nuclear









# Case 3) no nuclear, no coal

Note: GTCC plant replaces nuclear and coal







# Case 4) Renewable

Wind in the base and LBF-diesel in the peak load

CASE 4: RENEWABLE






# Total system costs and CO<sub>2</sub>-emissions



Alternative	Cost €/MWh	Emissions g/kWh
1) All options	69.6	53
2) No nuclear	86.8	834
3) No nuclear/coal	96.0	421
4) Renewable	86.9	0



# Profitability of alternatives

In the new electricity markets the price of electricity equals the variable costs of marginal plant (MC)

$$\text{Profits} = \text{Revenues} - \text{Costs}$$

where


$$\text{Revenues} = \sum (\text{MC}(t) \times E(t))$$

MC(t) = marginal costs at hour (t)


E(t) = energy generation during hour (t)




# Maximization of profits




Fill the load duration curve so that the highest variable cost plant is operating in the peak and intermediate load and the lowest variable cost plant in the base load





# Case 5) Nuclear in base load and LBF diesel plant in peak load






# Case 6) Nuclear in base load and Gas engine plant in peak load







# Case 7) Wind in base load and LBF diesel plant in peak load








# Case 8) Wind in base load and Gas engine plant in peak load






# Profitability of alternative case systems

Case	Profits M€/a	Electricity price
1) All options	- 785	50.7 €
2) No nuclear	- 768	69.5
3) No nuclear/coal	- 791	79.0
4) Renewable	-1830	51.8
5) Nuclear/LBF diesel	+1730	114.5
6) Nuclear/Natural gas	+ 601	89.0
7) Wind/LBF diesel	+ 668	114.5
8) Wind/Natural gas	- 655	89.0



# Recommendations

- 1) Maximize the use CHP-plants because they have the lowest generation costs in the base and intermediate load
- 2) Fill the base load then with wind and nuclear plants up to 6000 h/a
- 3) Use gas fired plants in the intermediate load
- 4) Use LFO and LBF plants in the peak load




# Recommendations, continued




- 5) Select actual power plants only after studying the need of
- ancillary services
  - reserve power requirements

**The largest plant has largest need for  
ancillary services and reserves**



# Recommendations, continued


- be able to start-up in 5 - 10 min
- be able to participate in Automatic Generation Control (AGC)
- have high ramp rate



# Recommendations, continued




- 7) Build the power plants near the consumption centers to avoid transmission losses and need of reactive reserves



# Summary

- Power system can be optimised to give minimum costs or maximum profits
- The boundary conditions may be target to reduce CO<sub>2</sub>-emissions
- Optimal system has low variable cost plants in base load and flexible plants in the peak load




For details see reference text book  
**”Planning of Optimal Power Systems”**

Author:  
**Asko Vuorinen**

Publisher:  
**Ekoenergo Oy**

Printed:  
**2008 in Finland**

Further details and  
internet orders see:



[https://www.booky.fi/tuote/vuorinen\\_asko/planning\\_of\\_optimal\\_power\\_systems/9789526705712](https://www.booky.fi/tuote/vuorinen_asko/planning_of_optimal_power_systems/9789526705712)